



THE MOST **ADVANCED** NAME IN DRAINAGE SYSTEMS



July 10, 2020

RE: Lago Verde Mine – No. 57 Limestone

Mr. Jim Glover,

After reviewing the Soil Analysis dated 5/20/2020 from the Lago Verde Mine, the No. 57 Limestone is acceptable for use with our StormTech Chambers. The properties of this limestone meet the material requirements as outlined in StormTech's Technical Note #4. (attached) This backfill material would be acceptable with the SC160, SC310, SC740, DC780 and MC3500 Chamber sizes.

If there are any questions, please do not hesitate to call.

Thank You,

John Trivento
Territory Manager - Tampa Metro Market
407-751-9389

Enc: StormTech Tech Note #4, Lago Verde Mine Soil Analysis 5/20/2020